

## Addendum #2

**Date:** Thursday, April 07, 2016  
**Project:** 16011 Current Products Corp. Offices  
**Recipients:** All Bidders  
**RE:** Addendum #2/ Letter of Clarification #2

---

For the benefit of all Contractors submitting Request for Information and to avoid possible confusion, the construction documents are clarified as follows. Please note this Letter of Clarification #2/Addendum #2 and all attachments are hereby incorporated into the construction documents.

### **A. CLARIFICATION**

**Question: On the windows, did you mean Zone 4/5? Isn't zone 3 for roofs?**

Answer: Wind Zone 3 refers to wind zone maps of the United States, not wind pressure zones for cladding. Pensacola is located in wind zone 3.

**Question: You ask for sound attenuation in the offices. Do you desire the same at the acoustical ceiling of the offices?**

Answer: Yes, provide 3 ½" unfaced acoustic batt insulation above acoustical ceilings.

Acknowledgement of receipt of this addendum will be required with your proposal.

This Letter of Clarification #2/Addendum #2 is hereby incorporated in the Proposal document and shall supersede any previous specification or provision in conflict with the Letter of Clarification #2/Addendum #2. All Vendors/Contractors are directed to respond accordingly. Vendors/Contractors are required to add this Letter of Clarification #2/Addendum #2 to the original Proposal document.