

Addendum #3

Date: Thursday, April 14, 2016
Project: 16011 Current Products Corp. Offices
Recipients: All Bidders
RE: Addendum #3/ Letter of Clarification #3

For the benefit of all Contractors submitting Request for Information and to avoid possible confusion, the construction documents are clarified as follows. Please note this Letter of Clarification #3/Addendum #3 and all attachments are hereby incorporated into the construction documents.

A. CLARIFICATION

Question: I couldn't find in the plans where it calls out the color of the glass for the storefront. Was it clear or grey?

Answer: The glass is clear with a maximum SHGC of 0.40.

Additionally, the owner requests an additive alternate (#4) to replace the existing 12'-0" x 14'-0" overhead coiling door at the new R&D lab with an impact-rated, polyurethane-insulated overhead coiling door. The new door should be powder-coated galvanized steel with a minimum R-value of 7, equivalent to Wayne-Dalton Thermotite 800C.

Acknowledgement of receipt of this addendum will be required with your proposal.

This Letter of Clarification #3/Addendum #3 is hereby incorporated in the Proposal document and shall supersede any previous specification or provision in conflict with the Letter of Clarification #3/Addendum #3. All Vendors/Contractors are directed to respond accordingly. Vendors/Contractors are required to add this Letter of Clarification #3/Addendum #3 to the original Proposal document.